



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-10279

Inspection Number: 03383680

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 8620 HUNTERS HILL LN LITTLETON

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 01/08/2018

Inspection Time: 12:00 AM

Inspection Type: Final HVAC

Inspection Code: 39

Outcome: Approved

Inspected By: Brian Brown

Charge Reinspection Fee: No