



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 17-09605  
Inspection Number: 03387266

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

Job Address: 11476 BONANZA CIR FRANKTOWN  
Job Type: Building  
Description: AU - Garage  
Scope of Work: New

### Inspection Details

Inspection Date: 01/29/2018  
Inspection Time: 12:00 AM  
Inspection Type: Final Building  
Inspection Code: 108  
Outcome: Disapproved  
Inspected By: Rich Garrett  
Charge Reinspection Fee: No

### Comments

H2.5s & truss calcs