



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 17-09605  
Inspection Number: 03387266

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 11476 BONANZA CIR FRANKTOWN  
**Job Type:** Building  
**Description:** AU - Garage  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 01/29/2018  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Building  
**Inspection Code:** 108  
**Outcome:** Disapproved  
**Inspected By:** Rich Garrett  
**Charge Reinspection Fee:** No

### Comments

H2.5s & truss calcs