



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 18-00472

Inspection Number: 03389049

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 9645 RED OAKES LN HIGHLANDS RANCH

**Job Type:** Building

**Description:** RS - Basement

**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 02/07/2018

**Inspection Time:** 12:00 AM

**Inspection Type:** Rough Electric

**Inspection Code:** 22

**Outcome:** Disapproved

**Inspected By:** Matt Mazzara

**Charge Reinspection Fee:** No

### Comments

- 1) Remove all old wiring
- 2) Sub feed incomplete
- 3) Stair switches incomplete

OK to insulate pending frame