



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-09605
Inspection Number: 03389335

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 11476 BONANZA CIR FRANKTOWN
Job Type: Building
Description: AU - Garage
Scope of Work: New

Inspection Details

Inspection Date: 02/07/2018
Inspection Time: 12:00 AM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Approved
Inspected By: Rich Garrett
Charge Reinspection Fee: No