



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 18-00472

Inspection Number: 03390475

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

Job Address: 9645 RED OAKES LN HIGHLANDS RANCH

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

### Inspection Details

Inspection Date: 02/13/2018

Inspection Time: 12:00 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Approved

Inspected By: Matt Mazzara

Charge Reinspection Fee: No

### Comments

#6 SER 40 amp max in insulation sub feeder. Check at final