



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 18-00472

Inspection Number: 03390476

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 9645 RED OAKES LN HIGHLANDS RANCH

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 02/13/2018

Inspection Time: 12:00 AM

Inspection Type: Insulation Thermal

Inspection Code: 36

Outcome: Approved

Inspected By: Chris Fuller

Charge Reinspection Fee: No