



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 18-00472
Inspection Number: 03390861

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 9645 RED OAKES LN HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 02/13/2018
Inspection Time: 2:19 PM
Inspection Type: Drywall
Inspection Code: 38
Outcome: Cancelled
Inspected By: UnassignedBldg
Charge Reinspection Fee: No

Comments

Cancelled by Web user.