



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: [dcbuilding@douglasco.gov](mailto:dcbuilding@douglasco.gov)

Permit Number: 14-02491  
Inspection Number: 03393369

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 10010 S PERRY PARK RD LARKSPUR  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 02/28/2018  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Interior Gas Line  
**Inspection Code:** 30  
**Meter Release:** No  
**Provider:**  
**Outcome:** Approved  
**Inspected By:** Clayton Rodeback  
**Charge Reinspection Fee:** No