



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-02491
Inspection Number: 03394891

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 10010 S PERRY PARK RD LARKSPUR
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 03/09/2018
Inspection Time: 7:52 AM
Inspection Type: Rough Energy Compliance
Inspection Code: 129
Outcome: Cancelled
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

will do at insulation insp.