



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 17-07906
Inspection Number: 03395461

Building Inspection Report

Permit Information

Job Address: 4200 MOHAWK DR LARKSPUR
Job Type: Mechanical
Description: Air Conditioner (Primary Residence)

Inspection Details

Inspection Date: 03/12/2018
Inspection Time: 12:00 AM
Inspection Type: Air Conditioner
Inspection Code: 55
Outcome: Approved
Inspected By: Rick Sugar
Charge Reinspection Fee: No