



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 18-00824  
Inspection Number: 03399982

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 2112 RIDGE PLAZA CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 04/02/2018  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Rough Frame  
**Inspection Code:** 29  
**Outcome:** Disapproved  
**Inspected By:** Kerry Keller  
**Charge Reinspection Fee:** No

### Comments

- 1) Need H2o shut off at pot filler
- 2) S-trap at Bibet drain
- 3) Need mixing valve master tub
- 4) Need Tempered glass at master tub windows