



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 18-00824
Inspection Number: 03400741

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 2112 RIDGE PLAZA CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 04/06/2018
Inspection Time: 7:49 AM
Inspection Type: Interior Gas Line
Inspection Code: 30
Meter Release:
Provider:
Outcome: Cancelled
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

res