



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 18-00824
Inspection Number: 03400742

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 2112 RIDGE PLAZA CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 04/05/2018
Inspection Time: 12:00 AM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Approved
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

Need tempered glass by final