Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 18-04656
Inspection Number: 03416312

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 14000 KENNETH LOOP PARKER
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 06/14/2018
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: David Lewis
Charge Reinspection Fee: No

Comments

no acess 9:06am