



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 18-05621  
Inspection Number: 03419303

## Building Inspection Report

### Permit Information

**Job Address:** 9425 CROSSLAND WAY HIGHLANDS RANCH  
**Job Type:** Mechanical  
**Description:** Furnace/AC Combo (Primary Residence)

### Inspection Details

**Inspection Date:** 06/26/2018  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Air Conditioner  
**Inspection Code:** 55  
**Outcome:** Approved  
**Inspected By:** Henry VanSchaack  
**Charge Reinspection Fee:** No