



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 18-05621
Inspection Number: 03419303

Building Inspection Report

Permit Information

Job Address: 9425 CROSSLAND WAY HIGHLANDS RANCH
Job Type: Mechanical
Description: Furnace/AC Combo (Primary Residence)

Inspection Details

Inspection Date: 06/26/2018
Inspection Time: 12:00 AM
Inspection Type: Air Conditioner
Inspection Code: 55
Outcome: Approved
Inspected By: Henry VanSchaack
Charge Reinspection Fee: No