



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 18-00824  
Inspection Number: 03425553

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 2112 RIDGE PLAZA CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 07/25/2018  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Henry VanSchaack  
**Charge Reinspection Fee:** No

### Comments

1) pendant light not permitted within 3' hor and 8' vert of tub rim; 2) led recess not permitted within 6" hor of shelf space; 3) secure flex within 12" of wall oven j-box; 4) open j-box at bottom of stairs