



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 18-00824  
Inspection Number: 03426225

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 2112 RIDGE PLAZA CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 07/27/2018  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Approved  
**Inspected By:** Henry VanSchaack  
**Charge Reinspection Fee:** No

### Comments

master closet shelf reduced to 12" for clearance and master bath pendant replaces with surface disc light