



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 18-01007

Inspection Number: 03429331

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 8466 FLINTWOOD RD PARKER

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 08/10/2018

Inspection Time: 12:00 AM

Inspection Type: Construction Meter

Inspection Code: 10

Meter Release:

Provider: IREA

Outcome: Disapproved

Inspected By: David Lewis

Charge Reinspection Fee: No

Comments

drive rod to 8ft

bond flex to meter enclosure

meter jumpers not permitted

float neutral on 4 wire feeder

cover service lateral for physical damage (ie plywood)

service at pole inspected & approved