Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 18-06726
Inspection Number: 03429763

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 14823 KONSTANZ AVE PARKER
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 08/13/2018
Inspection Time: 12:00 AM
Inspection Type: Drywall
Inspection Code: 38
Outcome: Approved
Inspected By: Richard Miller
Charge Reinspection Fee: No