



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 18-01007

Inspection Number: 03430239

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 8466 FLINTWOOD RD PARKER

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 08/15/2018

Inspection Time: 12:00 AM

Inspection Type: Electric Trench

Inspection Code: 16

Outcome: Approved

Inspected By: Justin Lett

Charge Reinspection Fee: No

Comments

No permit card on site

Maintain 24" burial depths entire distance to house-fix shallow spots

Leave trench open from temp location to house when service is done to check depth of feeders