



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 18-05910
Inspection Number: 03430670

Building Inspection Report

Permit Information

Job Address: 5998 APACHE DR LARKSPUR
Job Type: Mechanical
Description: Air Conditioner (Primary Residence)

Inspection Details

Inspection Date: 08/16/2018
Inspection Time: 12:00 AM
Inspection Type: Final HVAC
Inspection Code: 39
Outcome: Disapproved
Inspected By: Rick Sugar
Charge Reinspection Fee: No

Comments

Saddle valve not allowed at the humidifier