



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 18-08891  
Inspection Number: 03437972

## Building Inspection Report

### Permit Information

**Job Address:** 11931 DOGWOOD DR FRANKTOWN  
**Job Type:** Mechanical  
**Description:** Furnace/AC Combo (Primary Residence)

### Inspection Details

**Inspection Date:** 09/20/2018  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Approved  
**Inspected By:** Justin Lett  
**Charge Reinspection Fee:** No

### Comments

Strap FMC w/in 12" of switch and furnace-correct and proceed