



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 18-08891
Inspection Number: 03437973

Building Inspection Report

Permit Information

Job Address: 11931 DOGWOOD DR FRANKTOWN
Job Type: Mechanical
Description: Furnace/AC Combo (Primary Residence)

Inspection Details

Inspection Date: 09/20/2018
Inspection Time: 12:00 AM
Inspection Type: Air Conditioner
Inspection Code: 55
Outcome: Approved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

Seal penetration at line set-correct and proceed