



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 18-11270
Inspection Number: 03454336

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 9981 SPRING HILL PL HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 12/10/2018
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Matt Mazzara
Charge Reinspection Fee: No