



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 18-01266  
Inspection Number: 03455578

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 1510 N CASTLEWOOD CANYON RD FRANKTOWN  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 12/14/2018  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Electric Service Equipment Partial  
**Inspection Code:** 91  
**Meter Release:** No  
**Provider:** IREA  
**Outcome:** Approved  
**Inspected By:** Justin Lett  
**Charge Reinspection Fee:** No

### Comments

Panels at house ok-good to transfer. Leave hole open to inspect splices. Have docs on site listed for Dir Burial