



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 18-01266
Inspection Number: 03456538

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 1510 N CASTLEWOOD CANYON RD FRANKTOWN
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 12/19/2018
Inspection Time: 12:00 AM
Inspection Type: Exterior Underground Gas Line
Inspection Code: 32
Outcome: Approved
Inspected By: Rich Garrett
Charge Reinspection Fee: No