



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 18-01266
Inspection Number: 03457371

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 1510 N CASTLEWOOD CANYON RD FRANKTOWN
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 12/21/2018
Inspection Time: 12:00 AM
Inspection Type: Electric Service Equipment
Inspection Code: 23
Meter Release: Yes
Provider: IREA
Outcome: Approved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

Splices ok and DB rated