



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 18-01266
Inspection Number: 03464938

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 1510 N CASTLEWOOD CANYON RD FRANKTOWN
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 02/06/2019
Inspection Time: 10:37 AM
Inspection Type: Insulation Thermal
Inspection Code: 36
Outcome: Cancelled
Inspected By: Rich Garrett
Charge Reinspection Fee: No

Comments

not ready