



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 19-05487
Inspection Number: 03490223

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 3741 SERENADE RD CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 06/17/2019
Inspection Time: 8:43 AM
Inspection Type: Interior Gas Line
Inspection Code: 30
Meter Release:
Provider:
Outcome: Cancelled
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

n/a