



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-02491
Inspection Number: 03492367

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 10010 S PERRY PARK RD LARKSPUR
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 06/24/2019
Inspection Time: 8:14 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Cancelled
Inspected By: UnassignedBldg
Charge Reinspection Fee: No

Comments

Cancelled by Web user.