



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 14-02491  
Inspection Number: 03492372

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 10010 S PERRY PARK RD LARKSPUR  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 06/25/2019  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Rick Sugar  
**Charge Reinspection Fee:** No

### Comments

Breakers #8 in main panel and breakers #1,#11,#16 tripping not staying on  
Open generator dead front and exterior to inspect  
Breaker fillers at exterior panel  
Dead front on exterior panel missing  
Provide load calculation