



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-02491
Inspection Number: 03492372

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 10010 S PERRY PARK RD LARKSPUR
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 06/25/2019
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Rick Sugar
Charge Reinspection Fee: No

Comments

Breakers #8 in main panel and breakers #1,#11,#16 tripping not staying on
Open generator dead front and exterior to inspect
Breaker fillers at exterior panel
Dead front on exterior panel missing
Provide load calculation