



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 05-0944
Inspection Number: 00399610

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 8924 TAPPY TOORIE PL HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: New

Inspection Details

Inspection Date: 03/30/2005
Inspection Time: 12:00 AM
Inspection Type: Insulation Thermal
Inspection Code: 36
Outcome: Approved
Inspected By: Brian Brown
Charge Reinspection Fee: No