



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 05-0962
Inspection Number: 00399615

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 9921 STRATFORD LN HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: New

Inspection Details

Inspection Date: 03/24/2005
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Dave Ransom
Charge Reinspection Fee: No