



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 19-04695  
Inspection Number: 03505284

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 3741 SERENADE RD CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 08/26/2019  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Rough Electric  
**Inspection Code:** 22  
**Outcome:** Approved  
**Inspected By:** Justin Lett  
**Charge Reinspection Fee:** No

### Comments

Will need jbox at corner cabinet. Splice kit only acceptable for repairs, not wire extensions.