



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 19-06860
Inspection Number: 03507061

Building Inspection Report

Code Reviewed Under: 2012 IBC

Permit Information

Job Address: 16830 NORTHGATE DR # 100, PARKER
Job Type: Building
Description: CM - Tenant Finish
Scope of Work: Alteration

Inspection Details

Inspection Date: 09/03/2019
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Approved
Inspected By: Jim Dorsey
Charge Reinspection Fee: No