



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 19-04725
Inspection Number: 03507635

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 4354 IVYCREST PT HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 09/05/2019
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Approved
Inspected By: Matt Mazzara
Charge Reinspection Fee: No