



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 19-03109

Inspection Number: 03520906

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

Job Address: 12502 FIRST ST PARKER

Job Type: Building

Description: RS - Residential

Scope of Work: Addition

### Inspection Details

Inspection Date: 11/08/2019

Inspection Time: 12:00 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Disapproved

Inspected By: Henry VanSchaack

Charge Reinspection Fee: No

### Comments

1) max 10 openings per 15a ckt; 2) exterior light boxes not flush with siding; 3) nm must be 1-1/4" from face of framing in south hall; 4) outlet box required at front porch light

\*\*chain hung, pendant, track or ceiling fan not permitted in master closet, request service inspection\*\*