



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 19-03109

Inspection Number: 03522161

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 12502 FIRST ST PARKER

Job Type: Building

Description: RS - Residential

Scope of Work: Addition

Inspection Details

Inspection Date: 11/14/2019

Inspection Time: 12:00 AM

Inspection Type: Electric Service Equipment

Inspection Code: 23

Meter Release:

Provider:

Outcome: Disapproved

Inspected By: Henry VanSchaack

Charge Reinspection Fee: No

Comments

ufer letter not on file