



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 18-04232
Inspection Number: 03522517

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 1000 W NOE RD LARKSPUR
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 11/15/2019
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Rick Sugar
Charge Reinspection Fee: No