



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 19-04695
Inspection Number: 03524160

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 3741 SERENADE RD CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 11/22/2019
Inspection Time: 12:00 AM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Disapproved
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

- 1) Need to high loop your dish washer drain line
- 2) Cannot mix ABS to PVC at kitchen drains
- 3) Need AAV at kitchen sink and veg. sink
- 4) Complete fire rock and tape garage side
- 5) Adjust fire door closer to self close and latch
- 6) Complete weather strip and threshold fire door