



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 19-05487
Inspection Number: 03524161

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 3741 SERENADE RD CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 11/22/2019
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Approved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

See 19-04695