



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 19-13314
Inspection Number: 03527782

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 861 SWANDYKE DR CASTLE ROCK
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 12/13/2019
Inspection Time: 12:00 AM
Inspection Type: Interior Gas Line
Inspection Code: 30
Meter Release: No
Provider:
Outcome: Approved
Inspected By: Kerry Keller
Charge Reinspection Fee: No