



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 19-08891

Inspection Number: 03530208

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 9778 ADELAIDE CIR HIGHLANDS RANCH

**Job Type:** Building

**Description:** RS - Basement

**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 12/24/2019

**Inspection Time:** 12:00 AM

**Inspection Type:** Final Electric

**Inspection Code:** 42

**Outcome:** Approved

**Inspected By:** Matt Mazzara

**Charge Reinspection Fee:** No