



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 19-03620  
Inspection Number: 03537728

## Building Inspection Report

Code Reviewed Under: 2012 IBC

### Permit Information

**Job Address:** 13682I N STATE HIGHWAY 83 PARKER  
**Job Type:** Building  
**Description:** CM - Cell Site  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 02/06/2020  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Ufer Ground Electrode  
**Inspection Code:** 66  
**Outcome:** Approved  
**Inspected By:** Justin Lett  
**Charge Reinspection Fee:** No

### Comments

Ground ring around new equipment – pad was existing - tied back to Tower and existing ground ring as drawn