



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 19-13314
Inspection Number: 03545602

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 861 SWANDYKE DR CASTLE ROCK
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 03/26/2020
Inspection Time: 6:29 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Cancelled
Inspected By: Rick Sugar
Charge Reinspection Fee: No

Comments

Could not be at the house to do a virtual inspection