



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: [dcbuilding@douglasco.gov](mailto:dcbuilding@douglasco.gov)

Permit Number: 19-13314  
Inspection Number: 03547613

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 861 SWANDYKE DR CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Basement  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 04/07/2020  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Approved  
**Inspected By:** Damon Montroy  
**Charge Reinspection Fee:** No

### Comments

This inspection was done as a virtual inspection due to COVID19