Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 20-02076
Inspection Number: 03549972

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 10480 HARRISBURG ST PARKER
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 04/21/2020
Inspection Time: 12:00 AM
Inspection Type: Interior Gas Line
Inspection Code: 30
Meter Release:
Provider:
Outcome: Disapproved
Inspected By: Richard Miller
Charge Reinspection Fee: No

Comments

Need to permit water heater
Verify venting and gas sizing is correct